

Storm Damage Report (updated on 18.05.2022 till 11:00 P.M.)

Date of occurrence	District	Rev. Circle	Name of Village affected	No. of Village affected	Total Population affected	Houses Damaged				Any other Institutions affected	Human life lost	Crop Damage (In Hect)	Other loss (Livestock, Road Communication etc)	Ex-Gratia distributed	Time of death	GPS Co-ordinates	Remarks
						Partially Damaged		Fully damaged									
						Kutcha	Pucca	Kutcha	Pucca								
18-05-2022	Dhubri	Dhubri, Golakganj,	Dhubri R.C: Falimari Pt-I,Falimari Pt-II, Dhubirchar,Chagalchara Pt-I, Kuntirchar Pt-I,Chagalchara Pt-II, Jhagarpar Pt-I,Dhubri Town Khas Mahal,Bidyapara Pt-I. Golakganj: Gaikhuwa,Harihat,Uttar Kachkhana,Bisandoi Pt- I, Dakshin Tokrerchara Pt- III, Dakshin Tokrerchara Pt- IV, Dakshin Tokrerchara Pt- II, Lakhimari Pt- III, Pub Gaikhowa Pt- I, Pub Gaikhowa Pt- II	13	212	46	0	0	0	0	0	-	-	-	-	-	PSC Poles- 23 nos, Conductor- 14 KM, Transformer- 1 no under Dhubri R.C HT Pole : 5 Nos, LT Pole: 16 Nos. HT Conductor : 1.5 KM, LT Conductor : 3 KM under Golakganj R.C
18-05-2022	Bongaigaon	Srijangram	Srijangram: Kushbari Pt.I, Tinkonia Pt- III, Baghekhaity	3	16	0	0	3	0	0	0	-	-	-	-	-	
17-05-2022	Dhubri	Agomani, Athani	Agomani R.C: Bishkhowa Pt-1, Bishkhowa Pt-2, Bishkhowa Pt-3, Bishkhowa Pt-4, Bishkhowa Pt-5, Paschim Ratiya Daha Pt-1, Paschim Ratiya Daha Pt-2, Paschim Kanuri Pt-1, Paschim Kanuri Pt-2, Pub Kanuri Athani R.C: Sapatgram Pt-1, Sapatgram Pt-3, Sapatgram Pt-4, Bhelakoba Pt-III, Bherakhowa, Chenikhowa.	16	533	135	4	2	0	0	0	-	-	-	-	-	Sapatgram ESC under Fakiragram ESD Pole (7.5M)- 9 Nos, Conductor (LT)- 13.4 KM, Conductor(HT)-1.1 Km under Athani R.C. Due to storm huge nos of electrical equipment damaged in Agomani R.C Assessment of APDCL going on.
17-05-2022	Bongaigaon	Boitamari	Boitamari: Dolonibeel	1	0	0	0	0	0	1	0	-	-	-	-	-	Arabic LPS (Sur Gulshan Moktab) damaged under Boitamari R.C.
17-05-2022	Lakhimpur	Narayanpur Bihpuria	Narayanpur R.C: Deotala, Tarajuli. Bihpuria R.C: Badati Alimur	3	3	1	0	0	0	1	0	0	-	-	-	-	Bhogpur Chariali AWW Centre and APDCL- 1no PSC Pole(LT) damage. Narayanpur R.C.
17-05-2022	Sivasagar	Demow	Demow R.C: Bahuabari, Amlaguri, Koibortadoloni, Rajan Gaon, Athabari	5	0	0	0	0	0	1	0	-	-	-	-	-	Damaged under Demow Electrical Sub-Division as follows:- HT Pole- 2 nos. , LT pole :- 1 no., conductor : 600 m, Transformer (63 KVA) : 1 No., Transformer (25 KVA) :- 1 No.
Total				41	764	182	4	5	0	3	0	0	-	-	-	-	